

SCREENED GRAVEL

SECTION 107

1. GENERAL
2. GRAVEL
3. PLACING AND COMPACTING

1. GENERAL

- (a) The Contractor shall furnish, place and compact screened-gravel in authorized excavation below normal depth to stabilize trench base and elsewhere, as ordered by the Engineer.

2. GRAVEL

- (a) The material shall be screened gravel, well graded in size from 3/4 in. to No.4. The gravel shall consist of clean, hard, and durable particles or fragments, free from dirt, vegetable, or other objectionable matter, an excess of soft, thin elongated, laminated or disintegrated pieces. Crushed rock suitable size and grading may be used instead of screened gravel. The specifications which follow shall apply which-ever material is used. It shall conform to Connecticut DOT Form 816, M.01.01 (CT No. 67).

3. PLACING AND COMPACTING

- (a) The material shall be spread in layers of uniform thickness not greater than 6-in. And then shall be thoroughly compacted by means of a suitable static or other non-vibratory mechanical tamper.
 - (b) Conform to the requirements of Section 102 "Earth Excavation, Backfill, Fill and Grading" of these Specifications.

END OF SECTION