

CITY OF MIDDLETOWN
PURCHASING DEPARTMENT

ADDENDUM #1 TO BID #2015-011

BID #2015-011- Purchase of Piping, Hydrants, Manholes, Valves, Fittings and Other Appurtenances – Water and Sewer Department

Date Issued: May 21, 2015

ALL BIDDERS ARE HEREBY ADVISED OF THE FOLLOWING INFORMATION AND/OR MODIFICATIONS TO THE CONTRACT BID DOCUMENTS:

- Answers to questions submitted by deadline date of Tuesday, May 19, 2015 by 3:00 pm
- Bid Item # 30 revised (1" Combination Air/Vacuum Valve – ARI Model #D040)

INVITATION TO BID
Tuesday, May 26, 2015 at 11:00 AM EST

PLEASE VERIFY THAT YOU HAVE RECEIVED THIS NOTIFICATION IN THE SPACE BELOW AND FAX OR EMAIL THIS PAGE BACK TO THE PURCHASING DEPARTMENT.

FAX: 860-638-1995 EMAIL: purchase@middletownct.gov

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM #1: _____
COMPANY NAME

All bidders are hereby advised of the following amendments to the contract bid documents which are hereby made an integral part of the specifications for the subject project, prepared by the City of Middletown to the same extent as all other documents. All work shall conform to the standards and provisions of same. Bids submitted shall be deemed to include contract document information as shown in Addendum No. 1. General bidders shall notify sub-bidders that may be affected by this addendum as applicable. **Bidders shall be required to acknowledge receipt of this addendum in the space provided on the Bid Proposal Form.**

Failure to acknowledge receipt of this addendum by the bidder may result in the rejection of their bid. Bidders are directed to review changes to all portions of the work as changes to one portion may affect the work of another.

Total Addendum: 2 pages

*****BIDDER NOTE:** If you have already submitted a bid you shall be required to acknowledge receipt of this addendum under separate cover in a sealed envelope clearly marked with the bid number and description. This acknowledgment must be received by the time and date specified to be accepted by the City.

Donna L. Imme, CPPB
Supervisor of Purchases

ADDENDUM #1

BID #2015-011- Purchase of Piping, Hydrants, Manholes, Valves, Fittings and Other Appurtenances – Water and Sewer Department

Answers to questions submitted by deadline date of Tuesday, May 19, 2015 by 3:00 pm

Q: Item number 30 the factory said the following comment "A.R.I. Air valves for the Middletown Ct Bid. Due to the specifications calling for the valves to be made in North America and the body to be cast iron with stainless steel trim we are unable to quote you. A.R.I. is based in Israel and the bodies of the D-040 valves are reinforced nylon"

A: The following requirements are not applicable to bid item #30 (1" Combination Air/Vacuum Valve – ARI Model #D040):

- Made in America
- Cast iron body

Item #30 should be bid based on the above revisions.