

CITY OF MIDDLETOWN
PURCHASING DEPARTMENT

ADDENDUM #4 TO BID #2016-011

**BID #2016-011- Francis T. Patnaude Inter-Municipal Pumping Station
Mattabassett Regionalization Project – CT-DEEP CWF-487C**

Date Issued: August 4, 2016

**ALL BIDDERS ARE HEREBY ADVISED OF THE FOLLOWING INFORMATION AND/OR
MODIFICATIONS TO THE CONTRACT BID DOCUMENTS:**

- REISSUED DRAWING
- REISSUED SPECIFICATIONS
- FINAL ENGINEER RESPONSES

**PLEASE VERIFY THAT YOU HAVE RECEIVED THIS NOTIFICATION IN THE SPACE BELOW AND FAX
OR EMAIL THIS PAGE BACK TO THE PURCHASING DEPARTMENT.**

FAX: 860-638-1995 EMAIL: purchase@middletownct.gov

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM #4:

COMPANY NAME

All bidders are hereby advised of the following amendments to the contract bid documents which are hereby made an integral part of the specifications for the subject project, prepared by the City of Middletown to the same extent as all other documents. All work shall conform to the standards and provisions of same. Bids submitted shall be deemed to include contract document information as shown in Addendum No. 1, 2, 3, 4 and ALL addendums issued. General bidders shall notify sub-bidders that may be affected by this addendum as applicable. **Bidders shall be required to acknowledge receipt of this addendum in the space provided on the Bid Proposal Form.**

Failure to acknowledge receipt of this addendum by the bidder may result in the rejection of their bid. Bidders are directed to review changes to all portions of the work as changes to one portion may affect the work of another.

*****BIDDER NOTE:** If you have already submitted a bid you shall be required to acknowledge receipt of this addendum under separate cover in a sealed envelope clearly marked with the bid number and description. This acknowledgment must be received by the time and date specified to be accepted by the City.

Donna L. Imme, CPPB
Supervisor of Purchases

ADDENDUM #4 TO BID #2016-011

BID #2016-011- Francis T. Patnaude Inter-Municipal Pumping Station

Mattabassett Regionalization Project – CT-DEEP CWF-487C

BID ADDENDUM 4 - REISSUED DRAWINGS

Note: Bid Addenda modifications denoted with revision clouds shall be incorporated as a modification into the as-bid set of drawings.

1. S-10.1

BID ADDENDUM 4 - REISSUED SPECIFICATIONS

Note: Bid Addenda modifications denoted with revision clouds shall be incorporated as a modification into the as-bid set of specifications.

1. Section 2 – Bid Proposal (1 PAGE)
2. Section 700 – Measurement and Payment (10 PAGES)

FINAL ENGINEER RESPONSES

154. Ref. Section 104416 – Fire Extinguishers – Par. 2.1B Calls for a UL Rated 2-A:10-B:C 15.5lb nominal capacity but note on drawing A-0.1 it states to provide UL Rated 2-A:10-B:C 5lb fire extinguisher. What size fire extinguisher and type is required? Please clarify. **Typo on A-0.1. Provide 15.5#.**